

“Translated from Kannada to English”

Karnataka Government Monogram.
Department of Public Instruction of Government of Karnataka.

Office of the Deputy Director of Public Instruction Mandya District.

Certificate of Renewal of Recognition

Number: 40687

Date:29-Oct-2023

Subject: Issue of School Recognition framed under Karnataka Education Act and Children's Right to Education Act 2009.

With reference to the subject cited above school renewal recognition, Renewal of Recognition was sanctioned to Aryabhata International school 9th mile gate, Bidarahosahalli Road, Manigere, (K M Doddi) with disecode: 29220211133 run by the S V Educational and Charitable Trust registered management as per on verification of Documents by the Department officials and Spot Inspection and online application submitted by the School for renewal of Recognition.

S	Details	On line Application No.40687
1	Name of the Management and Address	S V Educational and Charitable Trust registered
2	Name and Address of the School	Aryabhata International school 9 th mile gate, Bidarahosahalli Road, Manigere, (K M Doddi)
3	DISE Code	29220211133
4	Classes	1-8 th
5	Medium.	English
6	Section	12
7	Type of School	Pvt-Unaided/Renewal of Recognition
8	Renewal of Recognition Year	From 2023-2024 to 2027-2028

Conditions:

1. School is registered under Karnataka Education act and Children's right to Education act 1983 rules and Regulations. Class of Registered School Recognition is renewed , Shall no run other then (Primary Education/Secondary Education)
2. School shall function under the Rules and regulations of Karnataka Education act and Children's right to Education act 2009.

3. Government has every right to fill 25% of seats reserved for under privileged category children under Children's Right to education act framed by the Government.(Government has framed provision of admission to Children in near by Government Grant in Aid schools where parents are residing other wise Private school situated near by have to admit students up to primary level.Shall not discriminate students admitted under RTE quota.
4. Government release fees of RTE Quota students and School should not Charges any fees from such students.
5. School managements shall not collect capitation from parents and donation in any form in future after admitting students.
6. School shall display school fees prescribed by the Government in their notice board and website. Should not Charge Excess fees then the prescribed fees.
7. Shall enroll students during the prescribed the period notified by the Government.
8. Should not deny enrollment of students in circumstances mentioned below:
 - (I) No Proof of Age
 - (II) On the basis of Caste, Creed, Birth place and mother tongue.
 - (III) After admission date prescribed.
9. Shall take precautionary measures ensuring safety of children as per RTE rule and regulations act(From concerned Authorities in respect of Fire safety and Building safety Certificates as per K.S,C.P.C and N.C.P.C.R for safety learning environment)
10. School managements Shall follow as detailed below:
 - (I) Shall not withhold or send out of schools during their Primary and middle school Education.
 - (II) Shall not put under Physical or Mental harassment.
 - (III) It is not necessary to promote in any Board Examination till completion of primary education.
 - (IV) Every Children Shall get Certificate as per RTE rules and regulation on Completion of Primary Education)
 - (V) Shall enroll all category of students irrespective of Physically disability/Special Children.
 - (VI) Shall appoint Qualified teaches as per qualification Prescribed for RTE rules and Regulations
 - (VII) Shall Pay remuneration and other allowances and Service rules and conditions a per Government Notification (Subject to Provident Fund (EPF) and disbursement of other allowances through Bank and Employees State Insurance(ESI))
 - (VIII) Staff appointed Shall discharge duties as per Children RTE rules and regulations and should not engage in Private Tuition's under any supervisions.
11. Shall follow syllabus and Text books prescribed by the affiliated Education authority.
12. Shall enroll students as per the facilities available in the School.

13. Shall recruit staff and follow under sections as per rules and regulations prescribed in Karnataka Education act.
14. Should not establish unauthorized class in and around the School Campus.
15. Should not permit Commercial activities or Political and other than Educational activities during night in the School Building and its facilities.
16. Should not run school for the benefit of any individual and organization.
17. Shall audit school accounts from the qualified auditors and same may submitted to concerned BEO/DDPI.
18. Shall follow language Policy as per Notification(Kannada Language Policy 2016)
19. Staff shall discharge duties as per RTE rules and Regulations.
20. School managements shall follow directions of Government rules and regulations without fail.
21. It is compulsory to up date students enrollment in SATS by end of March every year.
22. School recognition will be canceled in the event in case of breach of all the above said conditions as per RTE act 2009 and Karnataka Education Act 1983.

Sd/-

Deputy Director(Administration)
Department of Public Instruction.
Mandya (2922) District.

1. Concerned Management , The S V EDUCATIONAL AND CHARITABLE TRUST registered.
2. Head master, Aryabhata International School, Bidarahosahalli Road, Manigere(K M Doddi)
3. Block Education officer, Madduru (292202) Taluk/Zone District Mandya (2922).
4. Office Copy.

Digitally signed by H SHIVARAME GOWDA
Date: 2023.11.07 20:36:34+05:30

No:28:School/CC/DFO/MDY/2022-23

OFFICE OF THE
DISTRICT FIRE OFFICER,
MANDYA DIST, MANDYA .
Date: 16/12/2023

To,
The President,
Aryabhata International School,
9th Mile Gate, Bidarahosahalli Road,
Manigere Vilege, Bharathi Nagara,
Maddur Taluk, Mandya District.

Sir,

Sub:- Issue Renewal of Fire Safety Compliance certificate with respect to fire prevention, Fighting and evacuation measures maintained/required at **M/s Aryabhata International School**, 9th Mile Gate, Bidarahosahalli Road, Manigere Vilege, Bharathi Nagara, Maddur Taluk, Mandya District.

Ref:- 1. CN:23/FSR/DFO/MDY/2022, dated: 12/12/2022
2. No: 23:School/CC/DFO/MDY/2022 Dated: 22-12-2022
3. Your request letter dated: 27/11/2023.
4. C.No:36:/School FSR/DFO/MDY/2023 Dt 16-12-2023

With reference to the above cited subject, as per reference (1) a Fire Safety Recommendations Certificate was issued to the School management for the observations are rectified within 90 days.

As per reference (2) the School management rectified the observations, submitted the staffs training certificates and other requirements and 'Fire Safety Compliance Certificate' was issued.

Now as per reference (3) the School management submitted letter and requested for Renewal of Fire Safety Compliance Certificate..In this regard "**M/s Aryabhata International School**,, buildings situated at, 9th Mile Gate, Bidarahosahalli Road, Manigere Vilege, Bharathi Nagara, Maddur Taluk, Mandya District. was re-inspected by me on 13/12/2023 & As Per Ref (4) found that the School Management has been fulfilled the fire fighting systems, Except Fire training and the fire fighting systems are in good working condition during my inspection.

Hence, herewith issuing 'Renewal of Fire Safety Compliance Certificate' for the functioning of "**Aryabhata International School** " School buildings situated at, 9th Mile Gate, Bidarahosahalli Road, Manigere Vilege, Bharathi Nagara, Maddur Taluk, Mandya District for fire prevention, fire fighting and evacuation point of view. **This Renewal of 'Fire Safety Compliance Certificate' valid for only one year from the date of issued and is renewable.**

Yours faithfully,


District Fire Officer

Mandya District, Mandya
Karnataka Fire & Emergency Services
Mandya - 571 402



Copy with Compliments: 1. Submitted to The Director General Of Police & Director General Karnataka Fire And Emergency Sevices Bangalore.

C.No:36:/School FSR/DFO/MDY/2023

OFFICE OF THE
DISTRICT FIRE OFFICER,
MANDYA DIST, MANDYA .

Date: 16/12/2023

The President,
Aryabhata International School,
9th Mile Gate, Bidarahosahalli Road,
Manigere Villege, Bharathi Nagara,
Maddur Taluk, Mandya District.

Sir/Madam

Sub :- Issue of 'Fire safety recommendation' to M/s Aryabhata International School,
9th Mile Gate, Bidarahosahalli Road, Manigere Villege, Bharathi Nagara, Maddur
Taluk, Mandya District.

Ref :- Application of the applicant dated: 12/12/2023.

><<<*@*<<<<

With reference to the subject above cited, the premises M/s Aryabhata International School, 9th Mile Gate, Bidarahosahalli Road, Manigere Villege, Bharathi Nagara, Maddur Taluk, Mandya District. was inspected by me on 13/12/2023 with respect to Fire prevention, Fire fighting and Evacuation measures to be complied in the above premises and details as under.

ANNEXURE-1

(Up to 14.99 mtrs. In height)

Group B Educational Building

NBC-2016, Part-4, Table 7 (11) 3.1.3 Group B Educational Buildings Sub division B1 & B2.

(These condition are indicative and not exclusive all relevant provisions related to fire and life safety of NBC 2016 are mandatory)

A. Details of the building /premises :-

01	Name and Address of the Applicant.	:	The President, Aryabhata International School, 9 th Mile Gate, Bidarahosahalli Road, Manigere Villege, Bharathi Nagara, Maddur Taluk, Mandya District.
02	Name and Address of the premises.	:	Aryabhata International School, 9 th Mile Gate, Bidarahosahalli Road, Manigere Villege, Bharathi Nagara, Maddur Taluk, Mandya District
03	Name and address of the Building owner	:	The President, Aryabhata International School, 9 th Mile Gate, Bidarahosahalli Road, Manigere Villege, Bharathi Nagara, Maddur Taluk, Mandya District



04	Number of buildings	:	01 School Buildings.
05	Number of floors	:	Building- 1 Ground+ 03 Upper Floors
06	<u>Floor-wise details of occupancy:-</u>		
		:	Ground Floor:- 07 Class rooms, Office Room, Reception, Store Room First Floor :- 06 Class rooms, Office Room, Lab, Store Room, & 02 Wash Room. Second Floor :- 05 Class rooms, Library Office Room, Store Room, & 02 Wash Room. Third Floor:- 07 Class rooms, Staff room, Library, Lab, & Wash Room
07	Height of the building	:	12.67 mtrs
08	Site area	:	10420.00 Sq Mtrs
09.	Built-up area of each floor:-	:	Ground Floor:- 497.49 Sq. mtrs. First Floor:- 497.49 sq. mtrs. Second Floor:- 497.49 sq. mtrs. Third Floor:- 497.49 sq. mtrs 1989.96 Sq.mtrs
10.	Total built-up area	:	1989.96 Sq.mtrs.
11.	Surrounding properties:-		
	North (Front)	:	09.00 Mtrs Bidarahosahalli Road
	South (Rear)	:	Agriculture Land
	East (Side)	:	Agriculture Land
	WestSide)	:	Agriculture Land
12.	<u>Set-back area available around the building :-</u>		
	North (Front)	:	10.00 Mtrs
	South (Rear)	:	10.00 Mtrs
	East (Side)	:	15.00 Mtrs
	WestSide)	:	15.00 Mtrs

B. On inspection of this Educational premises, the following fire prevention, fire fighting and evacuation measures recommended are considered absolutely essential from fire safety point of view :-

Sl. No. (1)	Details (02)	Existing (03)	Recommendations (04)
01.	Accessibility to the premises	The Premises located in easy accessible place with 09.00 Mtrs Bidarahosahalli village Road There after it connects Maddur to Malavalli Main Road, leads to approach road towards Northern side This road is hardened to carry the weight of 45,000 kgs.	Complied.
02.	Number of	01 entrance & exit.	Complied.



	entrances		
03.	No. of staircases	Nos. of staircases : 01 nos. Width of staircases : 1.50 mtrs. Width of treads : 30 cms Height of risers : 15 cms Nos. of riser per flight : 12 nos. Height of handrails : 1.00 mtr.	Not Complied. Reccomanded to Provide Another Staircase to the Building
04.	Fire extinguisher	A. 02 water mist extinguishers of 9 ltrs capacity installed near staircase landing. B. One mechanical foam extinguishers of 9 ltrs capacity & one ABC type extinguishers of 6 kgs capacity provided near diesel generator. C. One CO2 type fire extinguisher, of 02 kgs capacity provided near electrical panel board D. 12 Nos ABC type fire extinguisher of 6 kgs capacity installed in School Building. The Systems was tested during inspection and found working satisfactorily.	Complied.
05	Hose reel hose system.	Provided as 04 No's of Hose Reel Hose near the Staircase The hose reel hose of 20 mm size and of 30 Mtrs length to reach the farthest point of each floor of building provided. Shut off branch having a nozzle of 5mm size. This system was connected to a terrace tank of 5,000 ltrs. Capacity with a Booster pump capable of delivering 450 liters of water per minute. The Systems was tested during inspection and found working satisfactorily.	Complied.
06	At the terrace tank level with minimum pressure of 3.5 kg/cm ² .	Provided one booster pump near overhead tank of capable of delivering 450 liters per minutes. The Systems was tested during inspection and found working satisfactorily.	Complied
	Diesel generators.	Provided 01 no. of diesel generator for alternative power supply to all the	Complied.



		emergency provisions of buildings.	
08.	Terrace tank	Provided 03 Nos overhead tank of 2,000 ltrs Capacities Each.	Complied The system is connected to an over head tank of 5000 ltrs capacity .
09.	Escape routes	Provided Marking Directions in which the Students & Staff have to move in the event of any emergency shall be indicated in the corridor during evacuation. It is written in luminous paint in every floor of building.	Complied.
10.	Fire order (Fire Safety plans)	A notice board written in bold letters indicating the action to be taken by the Students & Staff in case of any emergency is displayed near staircase and the notice board is contain telephone number of Maddur Fire Station 08232-200098 & 101 and ambulance service & Police station at near staircases of building as displayed	Complied.
11.	No Smoking board.	COPTA Sec-4 direction No Smoking area Smoking here is an offence board written in English & Kannada both languages . This is displayed at inside the entry / exit of the each floor.	Complied.
12.	Fire Siren	A Fire Siren installed in the premises to inform the intimates in case of a fire emergency and evacuate the area	Complied.
13.	Nominate one Fire Nodal Officer	A Fire Nodal Officer is nominated from one Non teaching Staff	Complied.
14.	Fire fighting training	Trained as. 1. Sri. M. Jayaramu 2. Sri. Sharath Kumar G.V. are trained in fire prevention, fire fighting and evacuation measures at The Regional training centre mysore, Hebbal Fire Station, Mysuru. From 25/05/2023 to 26/05/2023.	Not complied. 40% of the employees should be got trained in fire prevention, fire fighting and evacuation measures at R.A Mundkur Fire & Emergency Services Academy, Bannerghatta Road, Bangalore or Regional Training Center, Mysuru at an early date.

Fire precautionary measures.:-

Explosive and flammable material should not be stored in the store room, UPS room,



- Electrical panel area, class rooms, laboratory & electrical sum panel premises.
- B. Accumulation of combustible waste in and around the premises should be avoided.
- C. The exit ways shall be always kept clear without any obstruction.
- D. Liquefied petroleum gas should not be stored in the building.
- E. The doors shall not be kept locked / latched during working hours and shall be free from obstruction.
- F. During the class hours the class room doors shall not be locked from inside to outside.
- G. As per Hon'ble supreme court order all teachers and staffs shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety Day on April 14th of every year by conducting Fire Safety drills with co-ordinate with fire service department.

Under the above circumstance the Karnataka Fire & Emergency Service Department is issuing 'Fire Safety Recommendation' And Renewar of Fire Safety Complience Certificate to M/s Aryabhata International School, 9th Mile Gate, Bidarahosahalli Road, Manigere Village, Bharathi Nagara, Maddur Taluk, Mandya District. Subject to condition and compliance of the recommendations in column-4 of serial-B within 3 months and compliance to the undersigned.

"This Fire Safety Recommendation is valid up to only one year from the date of issued and is renewable".

All requirements recommended above are as per National Building Code-2016 Part-4 clause 3.1.3 of Fire and Life safety will have to be complied with mandatorily.



Yours faithfully


District Fire Officer

Mandya District, Mandya
Karnataka Fire & Emergency Services
Mandya - 571 402

C.No:23:/School FSR/DFO/MDY/2022

OFFICE OF THE
DISTRICT FIRE OFFICER,
MANDYA DIST, MANDYA .

Date: 12/12/2022

The President,
Aryabhata International School,
9th Mile Gate,Bidarahosahalli Road,
Manigere Villege, Bharathi Nagara,
Maddur Taluk, Mandya District.

Sir/Madam

Sub :- Issue of 'Fire safety recommendation' to M/s Aryabhata International School,
9th Mile Gate,Bidarahosahalli Road, Manigere Villege, Bharathi Nagara, Maddur
Taluk, Mandya District.

Ref :- Application of the applicant dated:06/12/2022.

><<<*@*<<<<

With reference to the subject above cited, the premises M/s Aryabhata International School, 9th Mile Gate,Bidarahosahalli Road, Manigere Villege, Bharathi Nagara, Maddur Taluk, Mandya District. was inspected by me on 08/12/2022 with respect to Fire prevention, Fire fighting and Evacuation measures to be complied in the above premises and details as under.

ANNEXURE-1

(Up to 14.99 mtrs. In height)

Group B Educational Building

NBC-2016, Part-4, Table 7 (11) 3.1.3 Group B Educational Buildings Sub division B1 & B2.

(These condition are indicative and not exclusive all relevant provisions related to fire and life safety of NBC 2016 are mandatory)

A. Details of the building /premises :-

01	Name and Address of the Applicant.	:	The President, Aryabhata International School, 9 th Mile Gate,Bidarahosahalli Road, Manigere Villege, Bharathi Nagara, Maddur Taluk, Mandya District.
02	Name and Address of the premises.	:	Aryabhata International School, 9 th Mile Gate,Bidarahosahalli Road, Manigere Villege, Bharathi Nagara, Maddur Taluk, Mandya District
03	Name and address of the Building owner	:	The President, Aryabhata International School, 9 th Mile Gate,Bidarahosahalli Road, Manigere Villege, Bharathi Nagara, Maddur Taluk, Mandya District



04	Number of buildings	:	01 School Buildings.
05	Number of floors	:	Building- 1 Ground+ 02 Upper Floors
06	<u>Floor-wise details of occupancy:-</u>		
		:	Ground Floor:- 07 Class rooms, Office Room, Reception, Store Room First Floor :- 06 Class rooms, Office Room, Lab, Store Room, & 02 Wash Room. Second Floor :- 05 Class rooms, Library Office Room, Store Room, & 02 Wash Room.
07	Height of the building	:	09.90 mtrs
08	Site area	:	10420.00 Sq Mtrs
09.	Built-up area of each floor:-	:	Ground Floor:- 497.49 Sq. mtrs. First Floor:- 497.49 sq. mtrs. Second Floor:- 497.49 sq. mtrs. 1492.47 Sq.mtrs
10.	Total built-up area	:	1492.47 Sq.mtrs.
11.	Surrounding properties:-		
	North (Front)	:	09.00 Mtrs Bidarahosahalli Road
	South (Rear)	:	Agriculture Land
	East (Side)	:	Agriculture Land
	WestSide)	:	Agriculture Land
12.	<u>Set-back area available around the building :-</u>		
	North (Front)	:	10.00 Mtrs
	South (Rear)	:	10.00 Mtrs
	East (Side)	:	15.00 Mtrs
	WestSide)	:	15.00 Mtrs

B. On inspection of this Educational premises, the following fire prevention, fire fighting and evacuation measures recommended are considered absolutely essential from fire safety point of view :-

Sl. No. (1)	Details (02)	Existing (03)		Recommendations (04)
01.	Accessibility to the premises	The Premises located in easy accessible place with 09.00 Mtrs Bidarahosahalli village Road There after it connects Maddur to Malavalli Main Road, leads to approach road towards Northern side This road is hardened to carry the weight of 45,000 kgs.		Complied.
02.	Number. of entrances	01 entrance & exit.		Complied.
03.	No. of staircases	Nos. of staircases	:	01 nos.
		Width of staircases	:	1.50 mtrs.
		Not Complied. Reccomanded to Provide Another Staircase to the Building		



		Width of treads	:	30 cms	
		Height of risers	:	15 cms	
		Nos. of riser per flight	:	12 nos.	
		Height of handrails	:	1.00 mtr. -	
04.	Fire extinguisher	Not provided			<p>Not complied.</p> <p>A. One water mist extinguishers of 9 ltrs capacity should kept near each staircase landing.</p> <p>B. One mechanical foam extinguishers of 9 ltrs capacity & one ABC type extinguishers of 6 kgs capacity should be provided near diesel generator.</p> <p>C. One CO2 type fire extinguisher, of 4.5 kgs capacity should be provided near each electrical panel board & electrical room.</p> <p>D. One ABC type fire extinguisher of 06 kgs capacity should be located as to be available within 15 mtrs radius.</p>
05	Hose reel hose system.	Not provided			<p>Recommended to One Hose Reel Hose near the staircase (One hose reel hose system for every 1000 Sq. mtrs). The hose reel hose of min 19 mm size and of 30 Mtrs length shall be provided to reach the farthest point of each floor and shut off branch having a nozzle of 5mm size. The hose reel hose should be connected at each landing of building.</p>
06	At the terrace tank level with minimum pressure of 3.5 kg/cm ² .	Not provided.			<p>Recommended to provide The System Should be connected to an Booster pump of 450 LPM or 5 HP Capacity.</p> <p>Further the system should be connected to an alternative source of power supply.</p>
07.	Diesel generators.	Not Provided			<p>Recommended to Provide Diesel Generator of 15 KVA capacity should be provided to supply alternative power supply.</p>
08.	Terrace tank	Not Provided			<p>Not complied.</p> <p>The system should be connected to an over head tank of 5000 ltrs capacity and further if basement is provided the tank capacity shall be increased to 10,000 ltrs capacity</p>



			<p>(The Water tank should be kept exclusively fire fight purpose) Note: If the existing building is not capable of sustaining the weight of 5,000 / 10,000 ltrs tank capacity provision shall be made to provide water tank on the side of the building with support from ground level by providing RCC column structure or MS Column structure. If there is no option to provide even the above mentioned overhead tank provision shall be made to provide underground water tank of capacity with submersible pump of 5-7 HP capacity.</p>
09.	Escape routes	Not marked.	Recommended to Marking. Directions in which the students & Staff have to move in the event of any emergency should be displayed in the corridor on each floor during evacuation.
10.	Fire order (Fire Safety plans)	Not displayed	Not complied. A notice board written in bold letters indicating the action to be taken by the Students And Staffs in case of any emergency should be displayed near staircase and the notice board should contain telephone number of Maddur Fire Station 08232-200098 & 101 and the telephone number of nearest ambulance service & Police station.
11.	No Smoking board.	Not displayed.	Not complied. COPTA Sec-4 direction No Smoking area Smoking here is an offence board should be written in English & Kannada both languages shall be prominently displayed at inside the entry / exit of the each floor.
12.	Fire Siren	Not installed	A Fire Siren Shall be installed in the premises to inform the intimates in case of a fire emergency and evacuate the area
13.	Nomenate one Fire Nodal Officer	Not provided	A Fire Nodal Officer shall be nominated either from teaching Or Non teaching Staff



14.	Fire fighting training	Not imparted	40% of the employees should be got trained in fire prevention, fire fighting and evacuation measures at R.A Mundkur Fire & Emergency Services Academy, Bannerghatta Road, Bangalore or Regional Training Center, Mysuru at an early date.
15	<p><u>Fire precautionary measures:-</u></p> <p>A. Explosive and flammable material should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory & electrical sum panel premises.</p> <p>B. Accumulation of combustibile waste in and around the premises should be avoided.</p> <p>C. The exit ways shall be always kept clear without any obstruction.</p> <p>D. Liquefied petroleum gas should not be stored in the building.</p> <p>E. The doors shall not be kept locked / latched during working hours and shall be free from obstruction.</p> <p>F. During the class hours the class room doors shall not be locked from inside to outside.</p> <p>G. As per Hon'ble supreme court order all teachers and staffs shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety Day on April 14th of every year by conducting Fire Safety drills with co-ordinate with fire service department.</p>		

Under the above circumstance the Karnataka Fire & Emergency Service Department is issuing 'Fire Safety Recommendation' M/s Aryabhata International School, 9th Mile Gate, Bidarahosahalli Road, Manigere Villege, Bharathi Nagara, Maddur Taluk, Mandya District. Subject to condition and compliance of the recommendations in column-4 of serial-B within 3 months and compliance to the undersigned.

"This Fire Safety Recommendation is valid up to only one year from the date of issued and is renewable".

All requirements recommended above are as per National Building Code-2016 Part-4 clause 3.1.3 of Fire and Life safety will have to be complied with mandatorily.



Yours faithfully

 District Fire Officer
 Mandya District, Mandya
 Karnataka Fire & Emergency Services
 Mandya - 571 402



GOVERNMENT OF KARNATAKA

**R.A. MUNDKUR FIRE AND EMERGENCY SERVICES ACADEMY
BANNERUGHATTA ROAD, BENGALURU - 560 029.**

-----<<<<.>>>>-----

*This is to certify that **Shri/Smt. M. JAYARAMU.**
Aryabhata International School, Bidara Hosahalli, Maddur
taluk, Mandya district, has under-gone basic training in
fire prevention and fire fighting from **25-05-2023 to 26-05-2023**
[**2 Days**] at Regional Training Centre, Hebbal Fire Station
Premises, Mysuru.*

Date: 03-06-2023

Place: Bengaluru


Commandant 03/6/23

R.A. Mundkur Fire & Emergency Services
Academy, Bannerughatta road,
Bengaluru - 560 029.

No. **2023 06 1824**



046




GOVERNMENT OF KARNATAKA

**R.A. MUNDKUR FIRE AND EMERGENCY SERVICES ACADEMY
BANNERUGHATTA ROAD, BENGALURU - 560 029.**

-----<<<<>>>>-----

*This is to certify that **Shri/Smt. SHARATH KUMAR. G.V.**
Aryabhata International School, Bidara Hosahalli, Maddur
taluk, Mandya district, has under-gone basic training in
fire prevention and fire fighting from **25-05-2023 to 26-05-2023**
[2 Days] at Regional Training Centre, Hebbal Fire Station
Premises, Mysuru.*

*Date: 03-06-2023
Place: Bengaluru*


Commandant 03/6/23

*R.A. Mundkur Fire & Emergency Services
Academy, Bannerughatta road,
Bengaluru - 560 029.*

No. 2023 06 1825



047