

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಇಂಜಿನಿಯರ್‌ರವರ  
ಕಛೇರಿ ಲೋಕೋಪಯೋಗಿ ಇಲಾಖೆ, ನಂ-2ನೇ  
ಉಪ ವಿಭಾಗ, ಮದ್ದೂರು.



Office of the Assistant Executive Engineer,  
Public Works Department, No-2 Sub  
Division, Maddur.

ಸಂ:ಸಕಾಇಂ:ಲೋಇ:ಉವಿನಂ-2:ಸ.ಇಂ:/969:2022-23

ದಿನಾಂಕ: 15-11-2022

ಗೆ,

ಅಧ್ಯಕ್ಷರು

ಆರ್ಯಭಟ ಇಂಟರ್ ನ್ಯಾಷನಲ್ ಶಾಲೆ

9ನೇ ಮೈಲಿ ಗೇಟ್, ಬಿದರಹೊಸಹಳ್ಳಿ ರಸ್ತೆ

ಮದ್ದೂರು ತಾ, ಮಂಡ್ಯ ಜಿಲ್ಲೆ.

ಮಾನ್ಯರೆ,

ವಿಷಯ:- ಶಾಲಾ ಕಟ್ಟಡ ಸುರಕ್ಷತಾ ಪ್ರಮಾಣ ಪತ್ರವನ್ನು ನೀಡುವ ಬಗ್ಗೆ.

ಉಲ್ಲೇಖ:-1) ಅಧ್ಯಕ್ಷರು ಆರ್ಯಭಟ ಇಂಟರ್ ನ್ಯಾಷನಲ್ ಶಾಲೆ 9ನೇ ಮೈಲಿ ಗೇಟ್,

ಬಿದರಹೊಸಹಳ್ಳಿ ರಸ್ತೆ ಮದ್ದೂರು ತಾ, ಮಂಡ್ಯ ಜಿಲ್ಲೆ ರವರ ಪತ್ರ

ದಿ:-21-10-2022.

2)ಸರ್ಕಾರದ ಪತ್ರ ಸಂ: ಇಡಿ 43 ಪಿಜಿಸಿ 2022 ದಿನಾಂಕ 18-05-2022.

\*\*\*\*\*

ಮೇಲಿನ ವಿಷಯಕ್ಕೆ ಸಂಬಂಧಿಸಿದಂತೆ ಉಲ್ಲೇಖಿತ ಪತ್ರದಲ್ಲಿ ಅಧ್ಯಕ್ಷರು ಆರ್ಯಭಟ ಇಂಟರ್ ನ್ಯಾಷನಲ್ ಶಾಲೆ 9ನೇ ಮೈಲಿ ಗೇಟ್, ಬಿದರಹೊಸಹಳ್ಳಿ ರಸ್ತೆ ಮದ್ದೂರು ತಾ, ಮಂಡ್ಯ ಜಿಲ್ಲೆ ರವರು ನಡೆಸುತ್ತಿರುವ ಆರ್ಯಭಟ ಇಂಟರ್ ನ್ಯಾಷನಲ್ ಶಾಲೆ ಕಟ್ಟಡದ ಸುರಕ್ಷತಾ ಪ್ರಮಾಣ ಪತ್ರ ನೀಡಲು ಉಲ್ಲೇಖಿತ ಪತ್ರ (1) ರಲ್ಲಿ ಕೋರಿರುತ್ತೀರಿ.

ಹಾಗಾಗಿ ಸದರಿ ಕಟ್ಟಡವನ್ನು ದಿನಾಂಕ 02-11-2022 ರಂದು ಈ ಕಛೇರಿಯ ಶಾಖಾಧಿಕಾರಿಗಳಾದ ಶ್ರೀ ನಂದಕುಮಾರ್ ಪರಿಶೀಲನೆ ನಡೆಸಿದ್ದು, ಸದರಿ ಕಟ್ಟಡವು ಮೇಲ್ನೋಟಕ್ಕೆ ಪರಿಶೀಲಿಸಿದಂತೆ ಸುಸ್ಥಿತಿಯಲ್ಲಿದೆ ಹಾಗೂ ತೃಪ್ತಿಕರವಾಗಿದೆ. ಹಾಗಾಗಿ ಸರ್ಕಾರದ ಉಲ್ಲೇಖಿತ ಪತ್ರ (2)ರಂತೆ ಕಟ್ಟಡವು ಸುರಕ್ಷಿತವಾಗಿರುವ ಬಗ್ಗೆ ಈ ಮೂಲಕ ಧೃಢೀಕರಿಸಿದೆ. ಹಾಗೂ ಈ ಕಟ್ಟಡವು ಒಂದೇ ಬ್ಲಾಕ್ ಆಗಿದ್ದು ಮೂರು ಅಂತಸ್ಥಿನ ಕಟ್ಟಡವಾಗಿದ್ದು, ಇದರ ಅವಧಿಯು ದಿನಾಂಕ 15-04-2022 ರಿಂದ 14-04-2027ರವರೆಗೆ ಇರುತ್ತದೆ.

ತಮ್ಮ ವಿಶ್ವಾಸಿ

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಇಂಜಿನಿಯರ್

ಲೋಕೋಪಯೋಗಿ ಇಲಾಖೆ, ನಂ-2ನೇ ಉಪವಿಭಾಗ,


ಮದ್ದೂರು.

**Formats for Application to be submitted by the Educational Organizations**

Sl. no.	Details	:	General Requirements
1.	<b>Name &amp; Address of the building.</b>	:	Aryabhata International School Bidarahahalli
2.	<b>Number of Stories approved in the sanction building Plan.</b>	:	2 <sup>nd</sup> Floor
3.	<b>Years of Construction.</b>	:	2019
4.	<b>Submission of Following documents are not mandatory for the building already constructed and working. But Mandatory for new Buildings</b>		
a.	Approved building plan from the competent authority	:	<b>Enclosed/Not Enclosed</b>
b.	Completion certificate duly signed by the supervision Engineer who is in charge of the building	:	<b>Enclosed/Not Enclosed</b>

Date: 21/10/2022

Place: Bidarahahalli


  
 Aryabhata International School  
 9th Mile Gate, Bidarahosahalli Road,  
 K.M. Daddi, Maddur Tal.

(seal and signature of the organization)

**Remarks of the inspecting Authority**

while inspecting the above School building the following maintainance work to be done Regularly

- Replace the Tap & Hole pipe in Toilets of Both Rooms
- Exit ways should be always kept clear with out obstruction.
- Clear the Dry Leaves, any vegetation on building Terrace which block the Rainwater Down pipe. & Tank Level should be safe for required pressure of water
- Take safety pre-caution about Electric wires in Computer Laboratory.

  
 (seal and signature of the Authority)

ಸಂ. ೨೨೦  
 ೨೦೨೨

**“Translated from Kannada to English”**

Government of Karnataka

Office of the Assistant Executive Engineer, Public Works Department, No-2 Sub Division,  
Maddur.

Number:969:2022-23

Date:15-11-2022

**From,**

President

Aryabhata International School

9th Mile Gate, Bidarahosahalli Road,

Maddur Taluk, Mandya District,

**Dear Sir/Madam,**

**Subject :-** About Assurance of School Building Safety Certificate.

**Reference :-**1) President Aryabhata International School 9th Mile Gate, Bidarahosahalli  
Road, Maddur Taluk, Mandya District Letter Date:-21-10-2022.

2) Government letter No: ED 43 PGC 2022 dated 18-05-2022.

With regard to above mentioned matter in the referred letter, the President has requested in the referred letter (1) to issue a safety certificate for the Aryabhata International School building 9th Mile Gate, Bidarahosahalli Road Maddur Taluk, Mandya District.

Mr. Nandakumar inspected the said building on 02-11-2022 as the branch officer of this office and the said building is in good condition and satisfactory as per superficial inspection. Therefore, it is hereby certified that the building is safe as per the reference letter (2) of the Government and this building is a single block G + 3floor building valid up to **15-04-2022 TO 14-04-2027**.

Yourself

Assistant Executive Engineer  
Public Works Department,  
No-2nd Sub-Division

Maddur.

*Translated from Kannada to English*  
*G.Mamatha*

**G. MAMATHA** B.Com.,LL.B  
Advocate & Notary  
Maddur- 571428



**“Translated from Kannada to English”**

<b>Formats of Application to be submitted by the Educational Organizations</b>		
<b>Sl no</b>	<b>Details</b>	<b>General Requirements</b>
1.	<b>Name &amp; Address of the building</b>	Aryabhata International school Bidarahosahalli Road, Manigere.
2.	<b>Number of Stories approved in the sanction building Plan.</b>	2 <sup>nd</sup> Floor
3.	<b>Years of Construction</b>	2019
4.	<b>Submission of Following documents are not mandatory for the building already constructed and working. But Mandatory for new Buildings</b>	
a.	Approved building plan from the competent authority	<b>Enclosed/Not Enclosed</b>
b.	Completion certificate duly signed by the supervision Engineer who is in charge of the building	<b>Enclosed/ Not Enclosed</b>

Date: 21/10/2022

Place: Bidarahosahalli

(seal and signature of the organization)

**Remarks of the inspecting Authority**

While inspecting the above school building the following maintenance work to be done Regularly

- Replace the Tap & Hall pipe in Toilets & Bath Rooms
- Exit ways should be always kept. Clear without obstruction.
- Clear the Dry Leaves, any vegetation on building Terrace which block & the Rain water Down pipes. & Tank Level should be rise for required pressure of water
- Take safety pre – caution about electric wires in computer Laboratory.

(seal and signature of the Authority)

Assistant Executive Engineer

Public work Department

No- 2<sup>nd</sup> sub division

Maddur.

*Translated from Kannada to English*

*G. MAMATHA*  
G. MAMATHA B.Com., LL.B.  
Advocate & Notary  
Maddur- 571423

